



ABN 23 054 687 035

Compliance testing in accordance with ISO/IEC 17025

Test Report: MTL22-006-ST

**Sound Power Level Test Report for the
Convair CTA250 – Low Fan Speed**

For Seeley International

Printed copies uncontrolled

TEST REPORT
Sound Power Level

Report Number: MTL22-006-ST

Issue Number: 1

Issue Notes: *First Release*

Tested by: Sam Brooke



Approved by: Sam Brooke

.....

Date of Issue: 24/03/2022

Total number of pages: 6

Testing Laboratory: **Meridian Test Laboratory**

Address: 112 O'Sullivan Beach Road, Lonsdale SA 5160, Australia

Test specification: ISO 9614-02

Test location: Meridian Test Laboratory (as per address above)

Test reference: MTL2-003

Date of receipt of test item: 5/02/2021

Date(s) of performing tests: 5/02/2021

Customer's name: **Seeley International**

Address: 112 O'Sullivan Beach Road, Lonsdale SA 5160, Australia

General disclaimer & notes:

The test results presented in this report relate only to the sample as received from the customer.

The sample from hereon in will be referred as the UUT (Unit Under Test).

Data provided by the customer will be clearly identified within the body of this report, and where applicable, further notes will be included if the information supplied can affect the validity of the results.

This report shall not be reproduced, except in full, without the written approval of the issuing Testing Laboratory.

Copyright © 2019 Meridian Test Laboratory (ABN 23 054 687 035).

Document Template Reference: MTLF04-C – Issue 3 – 19-12-2019

UUT

particulars:

Test Item
Description..... Fixed evaporative cooler

Trade Mark Convair

Manufacturer..... Seeley International

Model/Type
reference CTA250

Serial number N/A

Product sample
number SN2203-01 (Sample selected by the customer)

Power Ratings 115V / 60Hz

Dimensions
(mm)..... 1130 (L) x 650 (H) x 1130 (W)

Speed Setting Low

Operating Mode .. Cooling

Photograph of
UUT



1. Introduction

This report presents the results and test methodology of sound power levels undertaken on evaporative Coolers. The tests were conducted at Seeley International's Lonsdale facility in accordance with ISO 9614-02:1993 (Determination of Sound Power Levels of Noise Sources Using Sound Intensity – Part 2: Measurement Using Scanning Method).

2. Acoustic Environment

- a. Meridian Lab 1.
- b. Low ambient sounds.
- c. Sheet Metal Walls with Insulation.
- d. Sheet Metal Floor with Insulation.
- e. 2.2m clearance on all sides of unit.

3. Instrumentation

Equipment used to conduct this test is listed below:

Description	Model	Part No.
Brüel & Kjær Hand Held Analyser	2270	3003020
Sound Intensity Microphone Pair and Accessories	4191	2033424
Sound Intensity Probe Pre Amplifiers Head	2683	207879
Sound Intensity Probe Calibrator	4297	3085372
Sound Intensity Probe Handler	NA	NA
Sound Intensity Probe Extension	NA	NA

4. Measurement Setup & Procedure

The Meridian Test Laboratory Procedure MTLP35 (for Sound Testing) was followed for this testing. A summary of this procedure is listed below.

- a. Ensure the unit is powered and the water turned on.
- b. Allowed 1 Hour to stabilize.
- c. Selected suitable equipment configuration for test.
- d. Ensure the sound meter is calibrated.
- e. Take two (35 second) sound measurements for each face of the unit except the bottom, holding intensity probe parallel to unit at a distance of 1 meter while performing the scanning pattern (Note: Probe was supported via an antenna)
- f. When all sides have been measured, check the validity of the results using the Sound Meter software. Generate a report if acceptable, or repeat testing if the results are not acceptable.


The UUT (Cooler) was setup as per the photo below:



The cooler was installed with the fan motor shown below:



5. Test Results



Spd	Air inlet Sound Power Level (dB(A) re 1 pW) Third Octave Band Centre Frequency																				Total	
	100	125	160	200	250	315	400	500	630	800	1	1.25	1.6	2	2.5	3.2	4	5	6.3	8		10
	Hz	Hz	Hz	Hz	Hz	Hz	Hz	Hz	Hz	Hz	kHz	kHz	kHz	kHz	kHz	kHz	kHz	kHz	kHz	kHz		kHz
Low	41	28	47	45	43.1	45	48	47	46	48	46	46	45	43	40	38	34	33	30	27	19	47

Operational Speed	Air inlet Sound Power Level (dB(A) re 1 pW) Octave Band Centre Frequency							Total Sound Power Level dB(A) re 1pW
	125Hz	250Hz	500Hz	1kHz	2kHz	4kHz	8kHz	
	Low Speed	48	49	52	52	48	40	

END OF REPORT